

COUNTY OF ALBANY

**WATERVLIET SHAKER ROAD (CR157) PHASE III ROADWAY
IMPROVEMENT PROJECT**

RFB-2022-105

ADDENDUM #1

December 6, 2022

The following Addendum No. 1 consisting of two (2) pages (including this cover page) is hereby issued on the 6th day of December 2022, in connection with the Request for Bids 2022-105 as requested by the Albany County Department of Public Works.

COUNTY OF ALBANY

RFB-2022-105

**WATERVLIET SHAKER ROAD (CR157) PHASE III ROADWAY IMPROVEMENT
PROJECT**

ADDENDUM #1

The following information is provided as a result of a question(s) posed by vendor(s):

ITEM #1: Regarding the hydrant, are the bollards, valve and tee to be included in each item? Or are the valves, fittings and bollards paid under a separate item?

Response #1: The hydrant item, Item 663.1301, shall include all work required to install the hydrant as shown in the detail on Dwg. No. UTD-01, except for the valve/valve box and the 6" ductile iron pipe, which are paid for separately. The additional items shown on Utility Plan 7, DWG. UTP-07, have been put into the contract in the event that the valve is no longer functioning properly and needs to be replaced out to the main.

An amendment will be issued shortly with revised Dwgs. UTP-07 and UTD-01 to clarify.

End of Addendum #1